



**AAMA/WDMA/CSA 101/I.S.2/A440-05  
TEST REPORT**

**Rendered to:**

**EAGLE WINDOW & DOOR, INC.**

**SERIES/MODEL: 4020 Double Hung Transom  
with Insulated Impact Glazing  
PRODUCT TYPE: Aluminum Clad Fixed Wood Window  
with Insulated Impact Glazing**

<b>Title</b>	<b>Summary of Results</b>
Primary Product Designator	FW-R55* 1219 x 610 (48 x 24)
Design Pressure	2640 Pa (55.0 psf)
Negative Design Pressure	3120 Pa (65.0 psf)
Air Infiltration	<0.05 L/s/m <sup>2</sup> (<0.01 cfm/ft <sup>2</sup> )
Water Penetration Resistance Test Pressure	400 Pa (8.25 psf)
Uniform Load Structural Test Pressure	+3960, -4680 Pa (+82.5, -97.5 psf)
Forced Entry Resistance	Grade 40

**Test Completion Date:** 05/29/07

Reference must be made to Report No. 73111.01-201-44, dated 09/27/07 for complete test specimen description and data.