



**AAMA/WDMA/CSA  
TEST REPORT**

**Rendered to:**

**EAGLE WINDOW & DOOR, INC.**

**PRODUCT TYPE: Series 05 Clad Outswing French Door Transom  
with Harbor Master Mono**

**SERIES/MODEL: Aluminum Clad Wood Transom Window with Impact Glass**

<b>Title</b>	<b>Summary of Results</b>
AAMA/WDMA/CSA 101/I.S.2/A440-05	FW-LC60 1830 x 918 (72 x 36)
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG60 1830 x 918 (72 x 36)-FW
Design Pressure	2880 Pa (60.0 psf)
Negative Design Pressure	3120 Pa (65.0 psf)
Air Infiltration	<0.05 L/s/m <sup>2</sup> (<0.01 cfm/ft <sup>2</sup> )
Canadian Air Infiltration/Exfiltration Level	Fixed
Water Penetration Resistance Test Pressure	440 Pa (9.0 psf)
Uniform Load Structural Test Pressure	+4320, -4680 Pa (+90.0, -97.5 psf)
Forced Entry Resistance	Grade 10

**Test Completion Date:** 10/27/09

Reference must be made to Report No. 95125.02-201-18, dated 03/03/10 for complete test specimen description and data.