



**AAMA/WDMA/CSA  
TEST REPORT**

**Rendered to:**

**EAGLE WINDOW & DOOR, INC.**

**SERIES/MODEL: 79 x 24 Series 05 Ascent Clad Inswing French Door  
Transom ST2 Fixed  
PRODUCT TYPE: Aluminum Clad Transom Window**

<b>Title</b>	<b>Summary of Results</b>
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG60 2007 x 610 (79 x 24)-TR
AAMA/WDMA/CSA 101/I.S.2/A440-05	TR-C60 2007 x 610 (79 x 24)
101/I.S.2/NAFS-02	TR-C60 2007 x 610 (79 x 24)
Design Pressure	2880 Pa (60.15 psf)
Air Infiltration	0.10 L/s/m <sup>2</sup> (0.02 cfm/ft <sup>2</sup> )
Canadian Air Infiltration/Exfiltration Level	A3
Water Penetration Resistance Test Pressure	440 Pa (9.19 psf)
Uniform Load Structural Test Pressure	±4320 Pa (±90.23 psf)
Forced Entry Resistance	Grade 10

**Test Completion Date:** 12/08/08

Reference must be made to Report No. 87741.01-602-44 dated 12/16/08 for complete test specimen description and data.

5906 Saxon Avenue  
Schofield, WI 54476  
phone: 715-241-8624  
fax: 715-241-8425  
www.archtest.com