



**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

EAGLE WINDOW AND DOOR, INC.

**SERIES/MODEL: Series 05 Clad Ascent
Outswing French Double Door
PRODUCT TYPE: Aluminum Clad Wood
Side-Hinged Door (XX)**

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG60 2007 x 2421 (79 x 95)-SHD
AAMA/WDMA/CSA 101/I.S.2/A440-05	SHD-LC60 2007 x 2421 (79 x 95)
Design Pressure	2880 Pa (60.0 psf)
Air Infiltration	0.20 L/s/m ² (0.04 cfm/ft ²)
Water Penetration Resistance Test Pressure	440 Pa (9.00 psf)
Uniform Load Structural Test Pressure	±4330 Pa (±90.0 psf)
Forced Entry Resistance	Pass

Test Completion Date: 07/08/09

Reference must be made to Report No. 91692.01-201-44, dated 07/10/09 for complete test specimen description and data.

849 Western Avenue North
St. Paul, MN 55117
phone: 651-636-3835
fax: 651-636-3843
www.archtest.com