



**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

EAGLE WINDOW & DOOR, INC.

**SERIES/MODEL: Series 02 Clad Axiom Awning with Harbor Master Mono
PRODUCT TYPE: Aluminum Clad Wood Awning Window with Impact Glass**

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-05	AP-C70 1219 x 914 (48 x 36)
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG70 1219 x 914 (48 x 36)-AP
Design Pressure	3360 Pa (70.0 psf)
Negative Design Pressure	3840 Pa (80.0 psf)
Operating Force (in motion)	18 N (4.0 lbf)
Air Infiltration	<0.05 L/s/m ² (<0.01 cfm/ft ²)
Canadian Air Infiltration/Exfiltration Level	A3
Water Penetration Resistance Test Pressure	510 Pa (10.5 psf)
Uniform Load Structural Test Pressure	+5040, -5760 Pa (+105.0, -120.0 psf)
Forced Entry Resistance	Grade 10

Test Completion Date: 10/28/09

Reference must be made to Report No. 95126.02-201-18, dated 11/30/09 for complete test specimen description and data.