



**AAMA/WDMA/CSA 101/I.S.2/A440-08
TEST REPORT**

Rendered to:

EAGLE WINDOW & DOOR, INC.

**SERIES/MODEL: 3866 Retro Double Hung
PRODUCT TYPE: Aluminum Clad Wood Insert Double Hung**

Title	Summary of Results
Primary Product Designator	LC-PG55-H 1118 x 1981 (44 x 78)
Design Pressure	2640 Pa (55.0 psf)
Operating Force (in motion)	154 N (34.7 lbf)
Air Infiltration	0.56 L/s/m ² (0.11 cfm/ft ²)
Water Penetration Resistance Test Pressure	400 Pa (8.25 psf)
Uniform Load Structural Test Pressure	±3960 Pa (82.5 psf)
Forced Entry Resistance	Grade 10

Test Completion Date: 05/31/07

Reference must be made to Report No. 73124.01-201-44, dated 12/02/08 for complete test specimen description and data.