



**ASTM E 1886 and ASTM E 1996  
TEST REPORT**

**Rendered to:**

**EAGLE WINDOW AND DOOR**

**SERIES/MODEL: 3080 Series 05 Clad Outswing French Door SP1 with Harbor Master Mono  
Mulled to a 3080 Series 05 Clad Outswing French Door Sidelite SP1 with Harbor Master Mono**

**PRODUCT TYPE: Aluminum Clad Outswing Hinged Glass Door with Impact Glazing Muller  
to an Aluminum Clad Sidelite/Fixed Door**

**Report No.: 95123.03-201-18**  
**Test Dates: 10/23/09**  
**Through: 01/19/10**  
**Report Date: 01/19/10**  
**Test Record Retention Date: 10/23/13**



## ASTM E 1886 and ASTM E 1996 TEST REPORT

Rendered to:

EAGLE WINDOW AND DOOR  
2045 Kerper Boulevard  
Dubuque, Iowa 52001

Report No.: 95123.03-201-18  
Test Dates: 10/23/09  
Through: 01/19/10  
Report Date: 01/19/10  
Test Record Retention Date: 10/23/13

**Project Summary:** Architectural Testing, Inc. was contracted by Eagle Window and Door to perform and validate testing on a Series/Model 3080 Series 05 Clad Outswing French Door SP1 with Harbor Master Mono Muller to a 3080 Series 05 Clad Outswing French Door Sidelite SP1 with Harbor Master Mono, Aluminum Clad Outswing Hinged Glass Door with Impact Glazing Muller to an Aluminum Clad Sidelite/Fixed Door at the Architectural Testing, Inc. test facility in St. Paul, Minnesota. The samples tested met the performance requirements set forth in the referenced test procedures for a +2880/-2400 Pa (+60.0/-75.0 psf) Design Pressure with missile impacts corresponding to Missile Level D and Wind Zone 4. Test specimen description and results are reported herein. The samples were provided by the client.

**Test Procedures:** The test specimens were evaluated in accordance with the following:

*ASTM E 1886-02, Standard Test Method for Performance of Exterior Windows, Curtain Walls, Doors and Storm Shutters Impacted by Missile(s) and Exposed to Cyclic Pressure Differentials.*

*ASTM E 1996-02, Standard Specification for Performance of Exterior Windows, Glazed Curtain Walls, Doors and Storm Shutters Impacted by Wind Borne Debris in Hurricanes.*

*ASTM E 1886-05, Standard Test Method for Performance of Exterior Windows, Curtain Walls, Doors and Storm Shutters Impacted by Missile(s) and Exposed to Cyclic Pressure Differentials.*

*ASTM E 1996-05, Standard Specification for Performance of Exterior Windows, Glazed Curtain Walls, Doors and Storm Shutters Impacted by Wind Borne Debris in Hurricanes.*

**Test Specimen Description:**

**Series/Model:** 3080 series 05 Clad Outswing French Door SP1 with Harbor Master Mono Muller to a 3080 Series 05 Clad Outswing French Door Sidelite SP1 with Harbor Master Mono

**Product Type:** Aluminum Clad Outswing Hinged Glass Door with Impact Glazing Muller to an Aluminum Clad Sidelite/Fixed Door

**Overall Size:** 1905 mm (75") wide by 2421 mm (95-5/16") high

**Operable Door Size:** 927 mm (36-1/2") wide by 2421 mm (95-5/16") high

**Operable Panel Size:** 883 mm (34-3/4") wide by 2369 mm (93-1/4") high

**Daylight Opening Size:** 641 mm (25-1/4") wide by 2045 mm (80-1/2") high

**Fixed Door/Sidelite Size:** 927 mm (36-1/2") wide by 2421 mm (95-5/16") high

**Fixed Door/Sidelite Panel Size:** 883 mm (34-3/4") wide by 2369 mm (93-1/4") high

**Daylight Opening Size:** 641 mm (25-1/4") wide by 2045 mm (80-1/2") high

**Overall Area:** 4.6 m<sup>2</sup> (49.6 ft<sup>2</sup>)

**Finish:** Interior wood was natural; exterior aluminum cladding was painted.

**Operable Door Frame Construction:** The frame was comprised of aluminum extrusions slip fit over wood side and head jambs. At the head, the aluminum frame joints were mitered, sealed with silicone and secured with a corner key. The wood jambs were sealed with silicone and fastened with three #8 x 1-3/4" screws per corner. The sill was comprised of an aluminum extrusion slip-fit over a polyethylene / wood fiber composite material with an oak threshold. The sill was butted to the side jamb, sealed with silicone and fastened with three #8 x 1-3/4" screws per corner.

**Fixed Door/Sidelite Frame Construction:** The frame was comprised of aluminum extrusions slip fit over wood side and head jambs. At the head, the aluminum frame joints were mitered, sealed with silicone and secured with a corner key. The wood jambs were sealed with silicone and fastened with three #8 x 1-3/4" screws per corner. The sill was comprised of an aluminum extrusion slip-fit over a polyethylene / wood fiber composite material with an oak threshold. The sill was butted to the side jamb, sealed with silicone and fastened with three #8 x 1-3/4" screws per corner.

**Test Specimen Description:** (Continued)

**Operable Door Panel Construction:** The wood stiles and rails were joined by two 3/4" x 4" hardwood dowels secured with glue and one 2-1/2" brad. Extruded aluminum cladding was square-cut and butted at the corners, sealed with silicone and secured with a corner key and one #7 x 7/8" screw.

**Fixed Door/Sidelite Panel Construction:** The wood stiles and rails were joined by two 3/4" x 4" hardwood dowels secured with glue and one 2-1/2" brad. Extruded aluminum cladding was square-cut and butted at the corners, sealed with silicone and secured with a corner key and one #7 x 7/8" screw. The panel was secured to the frame with rigid PVC dual-durometer continuous spacer bracket that was secured to the frame with #8 x 3/4" screws spaced 76 mm (3") to 152 mm (6") from corners and 356 mm (14") to 406 mm (16") on center. The panel was set in a bed of perimeter sealant and secured through the spacer bracket with #8 x 1" screws spaced to 76 mm (3") to 152 mm (6") from corners and 356 mm (14") to 406 mm (16") on center. The panel bottom rail was secured with three anchor clips secured to the sill and the panel with #8 x 3/4" screws. The clips were spaced 152 mm (6") from each corner and midspan.

**Weatherstripping:**

<u>Description</u>	<u>Quantity</u>	<u>Location</u>
6 mm (1/4") foam filled vinyl bulb	1 Row	Top rail of panels
Q-lon leaf seal	1 Row	Perimeter of frame

**Glazing Details:** Both units utilized a 10.1 mm (0.397") thick monolithic unit fabricated from two nominal 3.9 mm (5/32") annealed sheets separated by a 2.3 mm (0.090") thick DuPont SentryGlas® Plus interlayer. The glass was set from the interior against an Instant Glaze II sealant and backfilled with silicone. Wood glazing stops with a single sided adhesive foam tape were utilized on the interior and secured with 1-1/4" brad nails spaced 25 mm (1") from each corner and 152 mm (6") to 203 mm (8") on center.

**Drainage:** No drainage was utilized.

**Test Specimen Description: (Continued)**

**Hardware:**

<u>Description</u>	<u>Quantity</u>	<u>Location</u>
Butt hinges	4	279 mm (11") and 914 mm (36") from top and bottom of the panel
Three point locking mechanism	1	Panel lock jamb
Latch and deadbolt strike	1	Lock jamb

**Reinforcement:** No reinforcement was utilized.

**Mullion:** The door and fixed door/sidelite were mullied together with a 51 mm (2") x 127 mm (5") LVL mullion. Each unit was secured to the LVL mullion with 1/2" x 1" - GC20 corrugated fasteners 51 mm (2") to 76 mm (3") from head and sill spaced 203 mm (8") on center. The door jamb was additionally secured to the mullion with two #10 x 2-1/2" screws through each hinge. The exterior was sealed with silicone and secured with an aluminum mullion cap that was snap fit into the frame accessory kerfs. The ends of the mullions were sealed with silicone.

**Installation:** The unit was installed within a wood test frame and secured with steel installation straps 152 mm (6") from each corner and mullion, and spaced 533 mm (21") on center on the jambs. Each installation strap was secured to the frames with four #8 x 5/8" screws and to the bucks, on the exterior and interior, with two #8 x 1-1/2" screws. The sill was set onto three beads of silicone sealant and each unit was secured a #8 x 2-1/2" screw through the sill spaced 152 mm (6") from each corner. The operable door jamb was additionally secured with two #10 x 2-1/2" screws through each hinge. The unit was sealed to the buck with silicone.

**Test Results:** The following results have been recorded:

**ASTM E 1886, *Large Missile Impact***

**Conditioning Temperature:** 21°C (70°F)  
**Missile Weight:** 4128 g (9.1 lbs)  
**Missile Length:** 2410 mm (94-7/8")  
**Muzzle Distance from Test Specimen:** 4.9 m (16 ft.)

**Test Unit #1**

**Impact #1:** Missile Velocity: 15.2 m/s (49.8 fps); orientation within  $\pm 5^\circ$  of horizontal

**Impact Area:** Center of glazing of active panel

**Observations:** Missile hit target area; no, rips, tears or penetrations

**Results:** Pass

**Impact #2:** Missile Velocity: 15.2 m/s (49.8 fps); orientation within  $\pm 5^\circ$  of horizontal

**Impact Area:** Lower right glazing corner of active panel

**Observations:** Missile hit target area; no, rips, tears or penetrations

**Results:** Pass

**Impact #3:** Missile Velocity: 15.3 m/s (50.1 fps); orientation within  $\pm 5^\circ$  of horizontal

**Impact Area:** Vertical and horizontal center of bottom rail of active panel

**Observations:** Missile hit target area; no, rips, tears or penetrations

**Results:** Pass

**Impact #4:** Missile Velocity: 15.2 m/s (49.9 fps); orientation within  $\pm 5^\circ$  of horizontal

**Impact Area:** Midspan of mullion

**Observations:** Missile hit target area; no structural damage

**Results:** Pass

**Impact #5:** Missile Velocity: 15.2 m/s (49.8 fps); orientation within  $\pm 5^\circ$  of horizontal

**Impact Area:** Center of glazing of sidelite

**Observations:** Missile hit target area; no, rips, tears or penetrations

**Results:** Pass

Test Results: (Continued)

ASTM E 1886, *Large Missile Impact*

Test Unit #1 (Continued)

**Impact #6:** Missile Velocity: 15.4 m/s (50.6 fps); orientation within  $\pm 5^\circ$  of horizontal

**Impact Area:** Lower left glazing corner of sidelite

**Observations:** Missile hit target area; no, rips, tears or penetrations

**Results:** Pass

**Impact #7:** Missile Velocity: 15.2 m/s (50.0 fps); orientation within  $\pm 5^\circ$  of horizontal

**Impact Area:** Vertical and horizontal center of bottom rail of sidelite

**Observations:** Missile hit target area; no structural damage

**Results:** Pass

Test Unit #2

**Impact #1:** Missile Velocity: 15.4 m/s (50.6 fps); orientation within  $\pm 5^\circ$  of horizontal

**Impact Area:** Center of glazing of active panel

**Observations:** Missile hit target area; no, rips, tears or penetrations

**Results:** Pass

**Impact #2:** Missile Velocity: 15.5 m/s (50.8 fps); orientation within  $\pm 5^\circ$  of horizontal

**Impact Area:** Upper right glazing corner of active panel

**Observations:** Missile hit target area; no, rips, tears or penetrations

**Results:** Pass

**Impact #3:** Missile Velocity: 15.5 m/s (50.8 fps); orientation within  $\pm 5^\circ$  of horizontal

**Impact Area:** Vertical and horizontal center of bottom rail of active panel

**Observations:** Missile hit target area; no, rips, tears or penetrations

**Results:** Pass

**Impact #4:** Missile Velocity: 15.2 m/s (50.0 fps); orientation within  $\pm 5^\circ$  of horizontal

**Impact Area:** Midspan of mullion

**Observations:** Missile hit target area; no structural damage

**Results:** Pass

**Test Results:** (Continued)

**ASTM E 1886, Large Missile Impact**

**Test Unit #2** (Continued)

**Impact #5:** Missile Velocity: 15.2 m/s (49.8 fps); orientation within  $\pm 5^\circ$  of horizontal

**Impact Area:** Center of glazing of sidelite

**Observations:** Missile hit target area; no, rips, tears or penetrations

**Results:** Pass

**Impact #6:** Missile Velocity: 15.3 m/s (50.1 fps); orientation within  $\pm 5^\circ$  of horizontal

**Impact Area:** Upper right glazing corner of sidelite

**Observations:** Missile hit target area; no, rips, tears or penetrations

**Results:** Pass

**Impact #7:** Missile Velocity: 15.4 m/s (50.6 fps); orientation within  $\pm 5^\circ$  of horizontal

**Impact Area:** Vertical and horizontal center of bottom rail of sidelite

**Observations:** Missile hit target area; no structural damage

**Results:** Pass

**Test Unit #3**

**Impact #1:** Missile Velocity: 15.2 m/s (49.9 fps); orientation within  $\pm 5^\circ$  of horizontal

**Impact Area:** Center of glazing of active panel

**Observations:** Missile hit target area; no, rips, tears or penetrations

**Results:** Pass

**Impact #2:** Missile Velocity: 15.1 m/s (49.7 fps); orientation within  $\pm 5^\circ$  of horizontal

**Impact Area:** Lower right glazing corner of active panel

**Observations:** Missile hit target area; no, rips, tears or penetrations

**Results:** Pass

**Impact #3:** Missile Velocity: 15.5 m/s (50.7 fps); orientation within  $\pm 5^\circ$  of horizontal

**Impact Area:** Vertical and horizontal center of bottom rail of active panel

**Observations:** Missile hit target area; no, rips, tears or penetrations

**Results:** Pass

**Test Results:** (Continued)

**ASTM E 1886, *Large Missile Impact***

**Test Unit #3 (Continued)**

**Impact #4:** Missile Velocity: 15.3 m/s (50.1 fps); orientation within  $\pm 5^\circ$  of horizontal

**Impact Area:** Midspan of mullion

**Observations:** Missile hit target area; no structural damage

**Results:** Pass

**Impact #5:** Missile Velocity: 15.2 m/s (49.9 fps); orientation within  $\pm 5^\circ$  of horizontal

**Impact Area:** Center of glazing of sidelite

**Observations:** Missile hit target area; no, rips, tears or penetrations

**Results:** Pass

**Impact #6:** Missile Velocity: 15.1 m/s (49.7 fps); orientation within  $\pm 5^\circ$  of horizontal

**Impact Area:** Lower right glazing corner of sidelite

**Observations:** Missile hit target area; no, rips, tears or penetrations

**Results:** Pass

**Impact #7:** Missile Velocity: 15.2 m/s (49.8 fps); orientation within  $\pm 5^\circ$  of horizontal

**Impact Area:** Vertical and horizontal center of bottom rail of sidelite

**Observations:** Missile hit target area; no structural damage

**Results:** Pass

**Test Results:** (Continued)

ASTM E 1886, *Air Pressure Cycling*

Test Unit #1

Design Pressure: +2880/-3600 Pa (+60.0/-75.0 psf)

**POSITIVE PRESSURE**

Pressure Range Pa (psf)	Number of Cycles	Average Cycle Time (seconds)	Observations
580 to 1440 (12.0 to 30.0)	3500	1.46	No additional damage or deglazing was observed.
0 to 1725 (0 to 36.0)	300	2.24	No additional damage or deglazing was observed.
1440 to 2300 (30.0 to 48.0)	600	1.02	No additional damage or deglazing was observed.
865 to 2160 (18.0 to 60.0)	100	2.16	No additional damage or deglazing was observed.

**NEGATIVE PRESSURE**

Pressure Range Pa (psf)	Number of Cycles	Average Cycle Time (seconds)	Observations
1080 to 3600 (22.5 to 75.0)	50	2.34	No additional damage or deglazing was observed.
1800 to 2160 (37.5 to 60.0)	1050	1.47	No additional damage or deglazing was observed.
0 to 2160 (0 to 45.0)	50	2.60	No additional damage or deglazing was observed.
720 to 1800 (15.0 to 37.5)	3350	1.74	No additional damage or deglazing was observed.

**Result:** Pass

**Test Results:** (Continued)

**ASTM E 1886, Air Pressure Cycling**

**Test Unit #2**

**Design Pressure:** +2880/-3600 Pa (+60.0/-75.0 psf)

**POSITIVE PRESSURE**

Pressure Range Pa (psf)	Number of Cycles	Average Cycle Time (seconds)	Observations
580 to 1440 (12.0 to 30.0)	3500	1.89	No additional damage or deglazing was observed.
0 to 1725 (0 to 36.0)	300	2.36	No additional damage or deglazing was observed.
1440 to 2300 (30.0 to 48.0)	600	1.75	No additional damage or deglazing was observed.
865 to 2160 (18.0 to 60.0)	100	2.85	No additional damage or deglazing was observed.

**NEGATIVE PRESSURE**

Pressure Range Pa (psf)	Number of Cycles	Average Cycle Time (seconds)	Observations
1080 to 3600 (22.5 to 75.0)	50	2.80	No additional damage or deglazing was observed.
1800 to 2160 (37.5 to 60.0)	1050	1.97	No additional damage or deglazing was observed.
0 to 2160 (0 to 45.0)	50	2.68	No additional damage or deglazing was observed.
720 to 1800 (15.0 to 37.5)	3350	1.94	No additional damage or deglazing was observed..

**Result:** Pass

**Test Results:** (Continued)

**ASTM E 1886, Air Pressure Cycling**

**Test Unit #3**

**Design Pressure:** +2880/-3600 Pa (+60.0/-75.0 psf)

**POSITIVE PRESSURE**

Pressure Range Pa (psf)	Number of Cycles	Average Cycle Time (seconds)	Observations
580 to 1440 (12.0 to 30.0)	3500	1.64	No additional damage or deglazing was observed.
0 to 1725 (0 to 36.0)	300	2.55	No additional damage or deglazing was observed.
1440 to 2300 (30.0 to 48.0)	600	1.68	No additional damage or deglazing was observed.
865 to 2160 (18.0 to 60.0)	100	2.83	No additional damage or deglazing was observed.

**NEGATIVE PRESSURE**

Pressure Range Pa (psf)	Number of Cycles	Average Cycle Time (seconds)	Observations
1080 to 3600 (22.5 to 75.0)	50	2.86	No additional damage or deglazing was observed.
1800 to 2160 (37.5 to 60.0)	1050	2.02	No additional damage or deglazing was observed.
0 to 2160 (0 to 45.0)	50	2.85	No additional damage or deglazing was observed.
720 to 1800 (15.0 to 37.5)	3350	1.89	No additional damage or deglazing was observed.

**Result:** Pass

**General Note:** Upon completion of testing, the specimens met the requirements of Section 7 of ASTM E 1996.

**Test Equipment:**

**Canon:** Constructed from steel piping utilizing compressed air to propel the missile

**Missile:** 2x4 Southern Pine

**Timing Device:** Electronic Beam Type

**Cycling Mechanism:** Computer controlled centrifugal blower with electronic pressure measuring device

**Deflection Measuring Device:** Linear transducers

Tape and film were used to seal against air leakage during structural testing. In our opinion, the tape and film did not influence the results of the test.

**Drawing Reference:** The test specimen drawings have been reviewed by Architectural Testing and are representative of the test specimen reported herein.


**List of Official Observers:**

<u>Name</u>	<u>Company</u>
Chad Cornell	Eagle Window & Door, Inc.
Jim Welter	Eagle Window & Door, Inc.
Mark D. Lewke	Architectural Testing, Inc.
Dax R. Stoehr	Architectural Testing, Inc.
Karl A. Lips-Eakins	Architectural Testing, Inc.
Eric J. Schoenthaler	Architectural Testing, Inc.

Detailed drawings, data sheets, representative samples of test specimens, a copy of this report, or other pertinent project documentation will be retained by Architectural Testing, Inc. for a period of four years from the original test date. At the end of this retention period, such materials shall be discarded without notice and the service life of this report will expire.


Results obtained are tested values and were secured by using the designated test methods. This report does not constitute certification of this product nor an opinion or endorsement by this laboratory. It is the exclusive property of the client so named herein and relates only to the specimen tested. This report may not be reproduced, except in full, without the written approval of Architectural Testing, Inc.

For ARCHITECTURAL TESTING, INC.



Digitally Signed by: Eric Schoenthaler

Eric J. Schoenthaler  
Project Manager



Digitally Signed by: Daniel A. Johnson

Daniel A. Johnson  
Director - Regional Operations

EJS/jb

Attachments (pages): This report is complete only when all attachments listed are included.

Appendix-A: WDMA Submittal forms (2)

Appendix-B: Drawings (35)