



**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

EAGLE WINDOW & DOOR, INC.

**SERIES/MODEL: 6080 Series 05 Clad Ascent French Sliding Door
PRODUCT TYPE: Aluminum Clad Sliding Glass Door**

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-05	SD-LC50 1822 x 2438 (71 x 96)
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG50 1822 x 2438 (71 x 96)-SD
Design Pressure	2400 Pa (50.0 psf)
Operating Force (in motion)	38 N (8.5 lbf)
Air Infiltration	0.51 L/s/m ² (0.10 cfm/ft ²)
Water Penetration Resistance Test Pressure	360 Pa (7.50 psf)
Uniform Load Structural Test Pressure	±3600 Pa (±75.0 psf)
Forced Entry Resistance	Grade 10

Test Completion Date: 11/24/09

Reference must be made to Report No. 96406.01-201-44, dated 07/30/10 for complete test specimen description and data.