

PRODUCT PERFORMANCE TEST REPORT

FOR:	Eagle Window & Door, Inc.	REPORT NO.:	B0001.08-201-44
	2045 Kerper Boulevard	TEST DATES:	06/06/11
	Dubuque, Iowa 52001	THROUGH:	06/17/11
		REPORT DATE:	07/21/11
		TEST RECORD RETENTION DATE:	06/06/15

PRODUCT TESTED: 3080 Series 05 Clad Ascent Inswing French Door Sidelite SL1 with Harbor Master IG

TEST METHODS: AAMA/WDMA/CSA 101/I.S.2/A440-05 and A440-08
 Air Infiltration per ASTM E 283
 Water Penetration per ASTM E 547
 Uniform Load Structural per ASTM E 330
 Forced Entry Resistance per ASTM F 588

RATINGS: SLT-C45 927 x 2438 (36 x 96), FD-C45 927 x 2438 (36 x 96), Class CW-PG45 927 x 2438 (36 x 96)-SLT and Class CW-PG45 927 x 2438 (36 x 96)-FD

RESULTS: DP +2400 / -3120 Pa (+50.0 / -65.0 psf)

<u>TEST</u>	<u>RESULTS</u>	<u>ALLOWED</u>
Air Infiltration @ 75 Pa (1.57 psf)	0.05 L/s/m ² (0.01 cfm/ft ²)	1.50 L/s/m ² (0.30 cfm/ft ²)
Water Penetration @ 330 Pa (6.75 psf)	No Leakage	No Leakage
Structural Performance @ +3600 Pa (+75.00 psf)	0.5 mm (0.02")	0.3% L = 2.5 mm (0.10")
@ -4680 Pa (-97.50 psf)	1.0 mm (0.04")	0.3% L = 2.5 mm (0.10")

REFERENCE: See ATI Report No. B0001.02-201-44 for complete test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client so named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

ARCHITECTURAL TESTING, INC

ARCHITECTURAL TESTING, INC

Eric J. Schoenthaler
Project Manager

Daniel A. Johnson
Director - Regional Operations