



**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

EAGLE WINDOW & DOOR, INC.

**SERIES/MODEL: 2080 Series 05 Clad Ascent Outswing French Door Venting Sidelight
PRODUCT TYPE: Aluminum Clad Wood Venting Sidelight**

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-05	SLT-CW50 622 x 2438 (24 x 96)
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG50 622 x 2438 (24 x 96)-SLT
Design Pressure	2400 Pa (50.0 psf)
Operating Force (in motion)	18 N (4.0 lbf)
Air Infiltration	0.30 L/s/m ² (0.06 cfm/ft ²)
Water Penetration Resistance Test Pressure	440 Pa (9.0 psf)
Uniform Load Structural Test Pressure	±3600 Pa (±75.0 psf)
Forced Entry Resistance	Grade 10

Test Completion Date: 11/24/09

Reference must be made to Report No. 96409.01-201-44, dated 12/30/09 for complete test specimen description and data.