



**AAMA/WDMA/CSA 101/LS.2/A440-08
TEST REPORT**

Rendered to:

EAGLE WINDOW & DOOR, INC.

**SERIES/MODEL: Double Hung 4080
PRODUCT TYPE: Aluminum Clad Wood Double Hung**

Title	Summary of Results
Primary Product Designator	LC-PG50-H 1219 x 2438 (48 x 96)
Design Pressure	2400 Pa (50.0 psf)
Operating Force (in motion)	150 N (33.7 lbf)
Air Infiltration	0.20 L/s/m ² (0.04 cfm/ft ²)
Water Penetration Resistance Test Pressure	400 Pa (8.25 psf)
Uniform Load Structural Test Pressure	±3600 Pa (75.0 psf)
Forced Entry Resistance	Grade 40

Test Completion Date: 07/20/07

Reference must be made to Report No. 75095.01-201-44 dated 12/08/08 for complete test specimen description and data.