



**AAMA/WDMA/CSA 101/I.S.2/A440-08
TEST REPORT**

Rendered to:

EAGLE WINDOW & DOOR, INC.

**SERIES/MODEL: 3056 Series 02 Clad Casement Vent with Piano Hinge
PRODUCT TYPE: Aluminum Clad Wood Casement Window**

Title	Summary of Results
Primary Product Designator	R-PG70-C 914 x 1676 (36 x 66)
Design Pressure	3360 Pa (70.0 psf)
Operating Force (in motion)	10 N (2.3 lbf)
Air Infiltration	<0.05 L/s/m ² (<0.01 cfm/ft ²)
Water Penetration Resistance Test Pressure	510 Pa (10.5 psf)
Uniform Load Structural Test Pressure	±5040 Pa (±105.0 psf)
Forced Entry Resistance	Grade 10

Test Completion Date: 08/07/07

Reference must be made to Report No. 75732.01-201-44, dated 12/04/08 for complete test specimen description and data.