



**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

EAGLE WINDOW & DOOR, INC.

**SERIES/MODEL: 3060 Series 02 Axiom Clad Casement Vent
with Harbormaster Monolithic Glazing
PRODUCT TYPE: Aluminum Clad Casement Window
with Impact Glazing**

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-05	C-R65 914 x 1829 (36 x 72)
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG65 914 x 1829 (36 x 72) - Type C
Operating Force	27 N (6.0 lbf)
Design Pressure	3120 Pa (65.0 psf)
Negative Design Pressure	3600 Pa (75.0 psf)
Air Infiltration	<0.05 L/s/m ² (<0.01 cfm/ft ²)
Canadian Air Infiltration/Exfiltration Level	A3
Water Penetration Resistance Test Pressure	470 Pa (9.75 psf)
Uniform Load Structural Test Pressure	+4680, -5400 Pa (+97.5, -112.5 psf)
Forced Entry Resistance	Grade 10

Test Completion Date: 04/29/09

Reference must be made to Report No. 90241.01-201-44 dated 05/08/09 for complete test specimen description and data.