



**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

EAGLE WINDOW AND DOOR INC.

**SERIES/MODEL: Series 05 Clad Ascent
Outswing French Door Transom ST2**

PRODUCT TYPE: Aluminum Clad Wood Transom

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-05	TR-C80 2007 x 610 (79 x 24)
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG80 2007 x 610 (79 x 24)-TR
Design Pressure	3840 Pa (80.0 psf)
Air Infiltration	<0.05 L/s/m ² (<0.01 cfm/ft ²)
Canadian Air Infiltration/Exfiltration Level	Fixed
Water Penetration Resistance Test Pressure	580 Pa (12.0 psf)
Uniform Load Structural Test Pressure	±5760 Pa (±120.00 psf)
Forced Entry Resistance	Grade 40

Test Completion Date: 06/22/09

Reference must be made to Report No. 91695.01-201-44, dated 07/13/09 for complete test specimen description and data.