



**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

EAGLE WINDOW AND DOOR, INC.

**SERIES/MODEL: Series 05 Clad Ascent
Outswing French Single Door with Handicap Sill
PRODUCT TYPE: Aluminum Clad Wood
Side-Hinged Door with Handicap Sill (X)**

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG60 1016 x 2410 (40 x 94)- LW SHD
AAMA/WDMA/CSA 101/I.S.2/A440-05	LW SHD-C60 1016 x 2410 (40 x 94)
Design Pressure	2880 Pa (60.0 psf)
Air Infiltration	0.15 L/s/m ² (0.03 cfm/ft ²)
Water Penetration Resistance Test Pressure	0 Pa (0 psf)
Uniform Load Structural Test Pressure	±4320 Pa (±90.0 psf)
Forced Entry Resistance	Pass

Test Completion Date: 07/08/09

Reference must be made to Report No. 91691.01-201-44, dated 07/10/09 for complete test specimen description and data.