



**AAMA/WDMA/CSA  
TEST REPORT**

**Rendered to:**

**EAGLE WINDOW & DOOR, INC.**

**SERIES/MODEL: 6-7 x 8-6 Series 05 Clad Ascent Inswing French Door**

**PRODUCT TYPE: Aluminum Clad In-Swing Double French Door**

<b>Title</b>	<b>Summary of Results</b>
101/I.S.2.NAFS-02	HGD-C30 2007 x 2591 (79 x 102)
AAMA/WDMA/CSA 101/I.S.2/A440-05	SHD-C30 2007 x 2591 (79 x 102)
AAMA/WDMA/CSA 101/I.S.2/A440-08	LC-PG30-SHD 2007 x 2591 (79 x 102)
Design Pressure	1440 Pa (30.0 psf)
Air Infiltration	0.15 L/s/m <sup>2</sup> (0.03 cfm/ft <sup>2</sup> )
Water Penetration Resistance Test Pressure	290 Pa (6.0 psf)
Uniform Load Structural Test Pressure	±2160 Pa (±45.0 psf)
Forced Entry Resistance	Pass

**Test Completion Date:** 07/10/08

Reference must be made to Report No. 82754.01-201-44 dated 07/15/08 for complete test specimen description and data.