



**AAMA/WDMA/CSA 101/I.S.2/A440-08
TEST REPORT**

Rendered to:

EAGLE WINDOW & DOOR, INC.

**SERIES/MODEL: 4040 Double Hung Transom
PRODUCT TYPE: Aluminum Clad Fixed Wood Window**

Title	Summary of Results
Primary Product Designator	R-PG55-FW 1219 x 1219 (48 x 48)
Design Pressure	2640 Pa (55.0 psf)
Air Infiltration	<0.05 L/s/m ² (<0.01 cfm/ft ²)
Water Penetration Resistance Test Pressure	400 Pa (8.25 psf)
Uniform Load Structural Test Pressure	±3960 Pa (±82.5 psf)
Forced Entry Resistance	Grade 10

Test Completion Date: 05/29/07

Reference must be made to Report No. 73123.01-201-44, dated 12/05/08 for complete test specimen description and data.