



**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

EAGLE WINDOW AND DOOR

SERIES/MODEL: 6080 Series 05 Clad Outswing French Door SP1 with Harbor Master Mono Muller to a 3080 Series 05 Clad Outswing French Door Sidelite SL1 with Harbor Master Mono

PRODUCT TYPE: Aluminum Clad Outswing Hinged Glass Door with Impact Glazing Muller to an Aluminum Clad Sidelite/Fixed Door

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-05	SHD-C60 2808 x 2421 (110 x 95) FD-C60 2808 x 2421 (110 x 95) SLT-C60 2808 x 2421 (110 x 95)
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG60 2808 x 2421 (110 x 95)-SHD Class CW-PG60 2808 x 2421 (110 x 95)-FD Class CW-PG60 2808 x 2421 (110 x 95)-SLT
Design Pressure	2880 Pa (60.0 psf)
French Door Negative Design Pressure	3120Pa (65.0 psf)
Fixed Door/Sidelite Negative Design Pressure	3600 Pa (75.0 psf)
Mullion Negative Design Pressure	3120Pa (65.0 psf)
Air Infiltration	0.05 L/s/m ² (0.01 cfm/ft ²)
Water Penetration Resistance Test Pressure	440 Pa (9.0 psf)
French Door Uniform Load Structural Test Pressure	+4320, -4680 Pa (+90.0, -97.5 psf)
Fixed Door/Sidelite Uniform Load Structural Test Pressure	+4320, -5400 Pa (+90.0, -112.5 psf)
Mullion Uniform Load Structural Test Pressure	+4320, -4680 Pa (+90.0, -97.5 psf)
Forced Entry Resistance	Grade 10

Test Completion Date: 01/19/10

Reference must be made to Report No. 95124.03-201-18, dated 01/19/10 for complete test specimen description and data.